

FIRE SPRINKLER SYSTEMS PLAN REVIEW *Checklist*



3715 Bridgeport Way W
University Place, WA 98466
PH: (253) 566-5656 FAX: (253) 460-2541

The following are the minimum requirements needed for submittal of fire sprinkler systems to be reviewed for approval. Additional information such as clean drawings and sectional building views will greatly increase the turn-around time.

- 1. Two sets of 1/4" or 1/8" scale shop drawings and any other information required below.
- 2. Plan shall have a detailed scope of work.
- 3. Describe the project such as new, tenant improvement, or remodel.
- 4. Provide a site drawing showing streets, building envelope, and point of compass.
- 5. Provide 2 sets of manufacturer's product information sheets for all pipe, valves, heads, bracing integrated with the system.
- 6. Provide 2 sets of seismic calculation design sheets.
- 7. Provide 2 sets of hydraulic calculations.
- 8. Provide 2 sets of fire sprinkler riser diagram.

For questions please call Rod Pearce, Fire Marshal at 253-460-5439.

Please note: Fire inspections are performed on Tuesdays and Wednesdays, or by prearranged appointment with Fire Marshal. Call 253-460-2540 to schedule an inspection.